

Suggested Specification
SECTION 10 26 13
Pawling Pro-Tek® Model CGFT-888-1HR

PART 1 GENERAL

1.01 SUMMARY

- A. This section includes the following wall protection system:
 - 1. Corner Guards
- B. Related Sections
 - 1. Section 10 26 16 - Bumper Guards
 - 2. Section 10 26 23 - Protective Wall Covering
 - 3. Section 10 26 33 - Door and Frame Protection
 - 4. Section 09 22 00 - Supports for Plaster and Gypsum Board

1.02 REFERENCES

- A. Abbreviations and Acronyms
 - 1. National Fire Protection Association (NFPA)
 - 2. American Society for Testing and Materials (ASTM)
 - 3. Underwriters Laboratories (UL)
 - 4. American National Standards Institute (ANSI)

1.03 SUBMITTALS

- A. General: Submit the following in accordance with Section 01 33 00 "Submittal Procedures".
- B. Product Data
 - 1. Data sheet illustrating product dimensions, options, and related components.
 - 2. Installation instructions.
- C. Samples for verification of design suitability, color, and finish.
 - 1. 12" (304) Long sample.
- D. Test reports from a qualified independent laboratory showing results in compliance to requirements indicated

1.04 QUALITY ASSURANCE

- A. Manufacturer to have no less than 5 years experience in the production of wall protection products having successful in-service performance.
- B. Color Control: Provide extruded and molded components that meet visual and colorimetric evaluation of color to a controlled standard.
 - 1. Colorimetric evaluation less than or equal to 1.0 CMC DE (Delta E) when measured under cool white fluorescent lighting.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Storage: Store wall protection products in original packaging. Protect from weather, extreme temperatures, and moisture.
 - 1. Maintain temperature during storage between 40°- 100°F (4°- 38°C).
 - 2. Store materials flat to prevent twisting or sagging of cartons.
- B. Handling: Take adequate measure to prevent damage to materials. Avoid exposure of plastic products to direct sunlight.

1.06 SITE CONDITIONS

- A. Ambient Conditions: Do not install wall protection products until installation areas are enclosed and weatherproof. HVAC system must be operational and maintaining temperature at 65°-75°F (18°-24°C) for at least 72 hours prior to installation.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Pawling Corporation
Architectural Products
32 Nelson Hill Rd
Wassaic, NY 12592
Tel: 800-431-3456
www.pawling.com

2.02 DESCRIPTION

- A. Model CGFT-888-1HR, 1 5/8" (41) x Partition Width x 1 5/8" (41) Flush mounted end-wall guard with continuous aluminum retainers, fire resistant barrier, flexible impact cushions, and 1/4" (6) radius snap-on plastic cover. Outer edges of retainers shall be tapered, ribbed, and perforated for drywall installation. Suitable for partition widths 4 7/8" (124) to 7 1/4" (184). Product is designed for full height, floor to ceiling installation. Available with optional CBI-888 aluminum insert for use with flexible cove base, standard in 4" (102) and 6" (152) length. Select color from manufacturer's standard or custom colors. Specify end-wall guard CG-11 for partial height installations and partition widths greater than 7 1/4" (184).

2.03 DESIGN AND PERFORMANCE CRITERIA

- A. Fire Endurance Rating:
 - 1. Corner guard assembly rated for 60 minutes (1HR), tested in accordance with ASTM E119.
- B. Flammability Characteristics: High impact vinyl components.
 - 1. Class A Interior wall finish (NFPA 101 Life Safety), tested in accordance with ASTM E84.
 - a. Flame Spread: 25 or less
 - b. Smoke Developed: 450 or less
 - 2. Classification of HB when tested in accordance with ASTM D635.
- C. Stain Resistance: High impact vinyl components.
 - 1. Material to be tested for stain resistance to various chemical reagents in accordance with ASTM D543.
- D. Bacterial and Fungal Growth: High impact vinyl components.
 - 1. Material must not support bacteria or fungal growth when tested in accordance with ASTM G21 and ASTM G22.
- E. Impact Resistance: High impact vinyl components.
 - 1. Izod impact strength ASTM D256 method A notched, 23.8 ft-lbs/in average with no break.
 - 2. Charpy impact strength ASTM D6110 notched, 26.1 ft-lbs/in average with no break.

2.04 MATERIALS

- A. Cover: Extruded high impact vinyl sheet, nominal 0.093" (2.4) thickness, colored throughout.
- B. Aluminum Retainer: Extruded aluminum, alloy 6063-T6 (ASTM B221), nominal 0.070" (1.8) thickness.
- C. Fire Resistant Barrier: Galvanized sheet metal, 24 gauge (ASTM A526/A527).
- D. Cove Base Insert: Factory formed aluminum sheet, alloy 5052-H32 (ASTM B209), nominal .125" (3) thickness.
- E. Impact Cushions: Extruded thermoplastic, 70 durometer Shore A.

2.05 FABRICATION

- A. Cover shall be factory formed from rigid vinyl sheet.
 - 1. Single piece fabrication to 120" (1440) in length, longer units will be in multiple sections.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Examine walls for availability of backing to ensure secure attachment of wall protection products.
- B. Verify that HVAC is operating and installation area temperature has been maintained between 65°-75°F (18°-24°C) for at least 72 hours prior to installation.
- C. Verify application of wall finishes has been completed in accordance with project finish plan.

3.02 PREPARATION

- A. Surface Preparation: Clean substrate to remove dust and debris.

3.03 INSTALLATION

- A. Acclimate materials to building conditions for at least 24 hours prior to installation.
- B. Install wall protection products in accordance with manufacturer's installation instructions.

3.04 PROTECTION

- A. Protect installed material from damage by other trades. Use materials that will not mark, stain, or leave residue on the product.